



10 ϕ DIAMETER DRAINAGE HOLES @ 50mm CENTRES DRILLED INTO BASE OF PIT.

SURCHARGE PIT

(PLAN VIEW)

NOTES:

1. ROOFWATER SURCHARGE PITS ARE TO BE CONSTRUCTED OVER SWALE SUBSOIL DRAINS OR BIORETENTION SYSTEMS.
2. PIT SIZES AND/OR VARYING PIPE CONNECTION DIAMETERS ARE AS FOLLOWS < 100mm ϕ -300x300mm < 225mm ϕ -450x450mm > 225mm ϕ -NOT SUITABLE FOR SURCHARGE PITS IN FOOTPATHS
3. DIMENSIONS IN MILLIMETRES (U.N.O.).

SURCHARGE PIT DETAIL

(ELEVATION)

Exhibition Draft of Land Development Guidelines March 2007

		THIS DRAWING IS NOT TO BE AMENDED WITHOUT REFERENCE TO STANDARDS COMMITTEE		CONTROLLED DOCUMENT	DO NOT SCALE TAKE FIGURED DIMENSIONS ONLY		STANDARD DRAWING ROOF WATER OUTLET TO SWALE
		No.	AMENDMENT	APPROVED	DATE	ISSUED	
GOLD COAST CITY COUNCIL PO BOX 5842 GOLD COAST MC 9729							MICROFILMED STANDARD DRAWING No. 05-02-008 ISSUE 2005 EDITION