



**NOTES**

1. THE MANHOLE COVER AND FRAME IS TYPICAL ONLY. COVERS AND FRAMES ARE TO COMPLY WITH COUNCIL'S STANDARD SPECIFICATION SS5.
2. ALL CONCRETE TO WALLS AND FLOOR TO BE GRADE N25.
3. FOR DETAILS OF MANHOLE ROOF SLABS REFER TO G.C.C.C. STD. DWG. Nos. 05-03-102 & 05-03-103.
4. MINIMUM 30 LONGITUDINAL FALL THROUGH MANHOLE.
5. ADDITIONAL SEEPAGE DRAIN OUTLETS TO BE PROVIDED IN WATER CHARGED GROUND AS DIRECTED BY THE COUNCIL'S REPRESENTATIVE.
6. PRECAST PROPRIETARY MANHOLE COMPONENTS APPROVED BY COUNCIL MAY BE USED.
7. ASPHALT THICKNESS TO MATCH NOMINATED PAVEMENT DESIGN.
8. ALL COVERS ARE TO HAVE THE WORD "STORMWATER" CAST ON THE TOP IN LETTERS 40 HIGH BY 25 WIDE AND RAISED 3mm FOR ADDITIONAL REQUIREMENTS REFER TO GCCC SPECIFICATION SS5.
9. WHERE BOLT DOWN COVERS ARE SPECIFIED ON THE PROJECT DRAWINGS COVERS TO BE IN ACCORDANCE WITH G.C.C.C. STD. DWG. NO. 05-07-205 EXCEPT THE LETTERING IS TO BE IN ACCORDANCE WITH NOTE 8 OF THIS DRAWING.
10. MANHOLES DEEPER THAN 3000 REQUIRE INDIVIDUAL DESIGN AND CERTIFICATION.
11. DIMENSIONS ARE IN MILLIMETRES UNLESS SHOWN OTHERWISE.



THIS DRAWING IS NOT TO BE AMENDED WITHOUT REFERENCE TO STANDARDS COMMITTEE					CONTROLLED DOCUMENT
No.	AMENDMENT	APPROVED	DATE	ISSUED	

DO NOT SCALE TAKE FIGURED DIMENSIONS ONLY	
DRAWN BY	TECHNICAL SERVICES BRANCH
PASSED	18/03/04
APPROVED	18/03/04

STANDARD DRAWING
<b>STORMWATER MANHOLES 1050 Dia TO 1500 Dia</b>

MICROFILMED
STANDARD DRAWING No. <b>05-03-101</b>
ISSUE 2005 EDITION