



**NOTES**

1. THE RPZ DEVICE SHALL CONFORM WITH THE FOLLOWING:
  - (a) BE REGISTERED WITH COUNCIL AND PROVIDED IN ACCORDANCE WITH AS3500.
  - (b) BE PROVIDED WITH A TWO PART PROTECTION COVER BOX OF 5 THICK ALUMINIUM SHEETING AS DETAILED.
  - (c) RPZ DEVICES SHALL BE EITHER A 25mm VALVETEC OR COMBRACO DEVICE OR AN ALTERNATIVE APPROVED BY COUNCIL'S BACKFLOW PREVENTION OFFICER.
  - (d) ONLY AN ENDORSED BACKFLOW PREVENTION OFFICER SHALL ACTIVATE THE SYSTEM.

TYPICAL RPZ DEVICE INSTALLATION  
SEMI-DIAGRAMMATIC



**Gold Coast City Council**  
GOLD COAST CITY COUNCIL  
PO BOX 5042  
GOLD COAST MC 9729

THIS DRAWING IS NOT TO BE AMENDED WITHOUT REFERENCE TO STANDARDS COMMITTEE

CONTROLLED DOCUMENT

DO NOT SCALE  
TAKE FIGURED DIMENSIONS ONLY

**STANDARD DRAWING**

MICROFILMED

DRAWN BY	G.C.W
PASSED	D. HAYMAN 08/07/08
APPROVED	R. WENT 08/07/08

**REDUCED PRESSURE ZONE DEVICE  
TYPICAL LAYOUT**

STANDARD DRAWING No.  
**08-07-126**  
ISSUE  
**2008 EDITION**

No.	AMENDMENT	APPROVED	DATE	ISSUED