



THIS DRAWING IS TO BE COMPLETED BY THE CONSULTANT AND SHALL FORM PART OF THE ENGINEERING DRAWINGS SUBMITTED TO COUNCIL FOR APPROVAL.

NOTE:

1. FOR TYPICAL CONSTRUCTION DETAILS REFER G.C.C.C. STD. DWG No. 08-07-125 TO 08-07-133.
2. THE SUPPLY AND INSTALLATION OF PUMPS, RISER PIPES, BENDS AND ALL ASSOCIATED FITTINGS SHALL COMPLY WITH COUNCILS STANDARD SPECIFICATION SS1.
3. THE RISER PIPE SHALL BE ϕ CEMENT MORTAR LINED DUCTILE IRON FLANGE CLASS UNLESS OTHERWISE APPROVED BY COUNCIL.
4. THE WET WELL DIAMETER AND LID DIMENSIONS HAVE BEEN DETERMINED ON THE BASIS OF TYPE, SIZE AND VOLUTE DIAMETER OF PUMPS AS FOLLOWS.....
5. THE HIGHEST RECORDED FLOOD LEVEL AS SUPPLIED BY COUNCIL IS R.L.
6. THE PROTECTIVE COATING SYSTEM SHALL BE.....
7. THE LEVEL AT WHICH THE CONTRIBUTING SEWERAGE SYSTEM OR THIS SEWERAGE PUMPING STATION WILL OVERFLOW IS



THIS DRAWING IS NOT TO BE AMENDED WITHOUT REFERENCE TO STANDARDS COMMITTEE				CONTROLLED DOCUMENT
No.	AMENDMENT	APPROVED	DATE	ISSUED

DO NOT SCALE TAKE FIGURED DIMENSIONS ONLY	
DRAWN BY	G.C.W
PASSED	D. HAYMAN 08/07/08
APPROVED	R. WENT 08/07/08

STANDARD DRAWING

SEWERAGE PUMP STATION DIAGRAMATIC LAYOUT

MICROFILMED
STANDARD DRAWING No. 08-07-134
ISSUE 2008 EDITION