



**NOTES:**

1. SLOTTED PIPES TO SUBSOIL DRAINS TO BE MINIMUM 100mm DIAMETER:
  - PVC PIPES AND FITTINGS FOR DRAIN, WASTE AND VENT APPLICATIONS, JOINT TYPE, SOLVENT WELDED, MINIMUM SEWER CLASS SN6 MANUFACTURED IN ACCORDANCE WITH AS1260.
  - FIBRE REINFORCED CONCRETE PIPE MINIMUM CLASS 1, MANUFACTURED TO AS4139. JOINT TYPE, RUBBER RING (SUPERTITE).
  - POLYOLEFIN PIPES MANUFACTURED IN ACCORDANCE WITH DRAFT A0308-2003-06-10 "POLYETHYLENE AND POLYPROPYLENE PIPES AND FITTINGS FOR DRAINAGE AND SEWERAGE APPLICATIONS".
2. BOLLARDS OR SAFETY BARRIERS AND LANDSCAPED BUFFERS ARE REQUIRED AROUND RAISED GRATES IN FOOTPATHS. ADEQUATE PROVISION IS TO BE PROVIDED FOR THE PASSAGE OF PEDESTRIANS AROUND RAISED GRATES TYPICALLY 1.8m MIN. CLEARANCE).
3. CONCRETE N25 IN ACCORDANCE WITH AS1379 AND AS3600.
4. FILTER MEDIA, TRANSITION LAYER AND DRAINAGE LAYER TO BE IN ACCORDANCE WITH SECTION 13.3 OF THE LAND DEVELOPMENT GUIDELINES.
5. DIMENSIONS IN MILLIMETRES (U.N.O.).



THIS DRAWING IS NOT TO BE AMENDED WITHOUT REFERENCE TO STANDARDS COMMITTEE			CONTROLLED DOCUMENT	DO NOT SCALE TAKE FIGURED DIMENSIONS ONLY
			DRAWN BY TECHNICAL SERVICES BRANCH	
			PASSED	/ /
			APPROVED	/ /
No.	AMENDMENT	APPROVED	DATE	ISSUED

<b>STANDARD DRAWING</b>		MICROFILMED
<b>ROAD VERGE LINEAR BIORETENTION DETAILS</b>		STANDARD DRAWING No. <b>05-02-609</b>
		ISSUE 2005 EDITION